

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1157:105 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Digital Monitoring Products, *2500 N. Partnership Blvd., Springfield MO 65803
Contact: Terry Shelton (417) 831-9362 Fax (417) 831-1325

DESIGN: Models XR200 and XR2400F combination fire and burglary alarm control unit. Automatic, manual, coded, noncoded, local, remote station, proprietary, central station, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

XR200, XR2400F	Main Board
349A, 350	Enclosure
320, 321, 322	Transformer Adaptor
460	Interface Adaptor
462N, 462P, 472, 481	Expansion Interface Cards
711, 711E, 714, 715	Zone Expanders
714-8, 714-16, 715-8, 715-16, *725	Zone Expander/*24V Zone Expander
716	Output Expander
717	Annunciator Module
670, 770, 771	Supervised Vacuum Fluorescent Keypad
690, 693, 790, 791, 793, 630F	Supervised LCD Keypad
869	Initiating Module
865, 866, 867	Indicating Module
893	Phone Module
710, *710F	Bus Splitter/Repeater Module
485, 485B	Access Control Interface Card
733	Wiegand Interface Module
736P	Radionics' Popit Interface Module
*iCOM	Internet Alarm Router

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as combination fire and burglary alarm control unit for use with separately listed electrically and functionally compatible initiating and indicating devices. This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition.

NOTE: For Fire Alarm Verification Feature, the maximum Retard/Reset/Restart (including smoke detector reset time) shall not exceed 30 seconds. *Rev. 05-08-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 5, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**